DRAFT

OKLAHOMA DEPARTMENT OF ENVIRONMENTAL QUALITY PERMIT TO SUPPLY RECLAIMED WATER

PERMIT NUMBER: RW20-018
ID NUMBER: S11502

PART I

In compliance with the Oklahoma Pollutant Discharge Elimination System (OPDES) Act, Title 27A OS § 2-6-201 *et seq.*, as amended, and the rules of the Oklahoma Department of Environmental Quality (DEQ) promulgated thereunder (see the Oklahoma Administrative Code (OAC) 252:627 and 252:656),

City of Sayre 102 W Main St Sayre, OK 73662

is hereby authorized to supply and reuse treated municipal wastewater, also known as reclaimed water, for land application at the facility located at approximately

Latitude: 35° 17' 22.92" N [GPS: NAD83] Longitude: 99° 36' 31.32" W [GPS: NAD83]

and within the boundaries of the permitted land application site(s) located at approximately

NW¹/₄ of Section 2

Township 9 North, Range 23 West, Iindian Meridian

Beckham County, Oklahoma.

The reclaimed water shall be used solely for the purpose of irrigation at the permitted land application sites, in accordance with applicable DEQ regulations.

This is a new permit to supply reclaimed water.

The issuance date of this permit is Month Date, Year.

This permit shall become effective Month Date, Year.

This permit and the authorization to supply treated wastewater shall expire at midnight Month Date, Year.

For the Oklahoma Department of Environmental Quality:

Michael B. Moe, P.E., Manager

Municipal Discharge and Stormwater Permit Section

Shellie R. Chard, Director

Water Quality Division

Water Quality Division

A. LIMITATIONS AND MONITORING REQUIREMENTS FOR CATEGORY 5 RECLAIMED WATER

1. Authorized Land Application Site

Site ID	Legal Description	Method of Irrigation	Approximate Total Area (Acres)	Approximate Irrigated Area (Acres)
R01 ^a	NW1/4 of the Section 2, Township 9 North, Range 23 West, IM, Beckham County, Oklahoma	Sprinkler	160.0	147.0

Site owned by the user JD and Evelyn Green, User ID No. RWID20-006.

2. Limitations and Monitoring Requirements

Beginning the effective date through the expiration date of the permit, the permittee is authorized to supply treated wastewater for pasture land irrigation in accordance with OAC 252:656 and OAC 252:627 and the following limitations and monitoring requirements:

Site ID	Parameter	Monitoring Requirements ^{a, b}	Monitoring Frequency	Monitoring Location	
R01	Flow (mgd)	Record	Daily ^c	Pump Station	

^a Pursuant to OAC 252:627-5-1(b), the supplier shall complete Water Reuse System Monthly Operation Report (MORs, DEQ Form 627-001) for each month for the land application site.

b	In accordance with OAC 252:619-1-4(f) and OAC 252:627-5-1(b), (d), and (e), the supplier shall complete
	DEQ Forms 619-001 Total Retention Lagoon Monthly Operating Report (MOR) and 627-001 Water
	Reuse Monthly Operating Report (MOR) for each land application site, maintain the MORs on-site for at
	least three (3) years, and make them available for review by DEQ upon request.

3. Record Keeping Requirements for Commercial Fertilizer

Site Name:

In compliance with OAC 252:627-3-4(b)(7), the permittee is required to keep record of the commercial fertilizer applied at each site for the life of the permit in the following format. These records shall be made available to the DEQ on request.

Date	Acreage Fertilized	Composition of Fertilizer (Nitrogen, Phosphorous, Potassium)	Amount of Fertilizer Applied

b When there is no supply of reclaimed water for the entire day, report "0" in the MOR, and write "No Supply" in the comments column.

In accordance with OAC 252:656-25-2(h), flow measurement for your land application site shall be accomplished by flow meters, or the calibration of pumps and installation of run-time meters. When no pumps are used, as with gravity flow lines, flow shall be calculated using the on and off times.

4. Prevention of Unauthorized Access to Land Application Site

The permittee shall ensure that all permitted land application sites are completely fenced at all times in accordance with OAC 252:627-3-4(a)(1).

5. Signage Requirements

Beginning from the effective date of the permit, the permittee shall comply with the following signage requirements:

- a. In accordance with OAC 252:656-27-4(a), all valves, outlets and appurtenances in the distribution system of reclaimed water shall have a sign "CAUTION: RECLAIMED WATER DO NOT DRINK."
- b. In accordance with OAC 252:627-3-4(a)(2), signs which describe the nature of the facility and advise against trespassing shall be posted on the perimeter of each permitted reclaimed water application site.

B. RESTRICTIONS FOR CATEGORY 5 RECLAIMED WATER

- 1. In accordance with OAC 252:627-3-4(b), irrigation with Category 5 reclaimed water is prohibited:
 - a. from a lagoon cell that receives raw sewage;
 - b. from any cell other than the one specified in the permit;
 - c. on any food crop that may be consumed raw;
 - d. on grain crops such as corn, wheat and oats, less than 30 days before harvest;
 - e. at rates that allow a discharge from the permitted water reuse site;
 - f. within 100 feet of the permitted boundary of the site;
 - g. at a rate that exceeds the nitrogen and phosphorus rates for the crop grown at the site;
 - h. at a rate that results in phytotoxicity;
 - i. when the reclaimed water has a dissolved oxygen concentration of less than 2.0 mg/L;
 - i. during periods of precipitation or while the soil is saturated or frozen;
 - k. on land having a slope greater than 5 percent; and
 - where there are berms or other barriers on a water reuse site that would cause the pooling or ponding of reclaimed water at the water reuse site, nor shall any berms or barriers impede the natural flow of stormwater from the site.
- 2. In accordance with OAC 252:656-27-2(b), systems shall be designed to ensure that direct and wind-blown spray from irrigation systems and other sources are confined to the designated irrigation areas. Category 5 reclaimed water systems shall also be designed to comply with the following minimum buffer zones and setback distances, with all distances being measured from the edge of the wetted perimeter of the irrigation area to the edge of the following features:
 - a. 300 feet from public wells;
 - b. 50 feet from private water wells;
 - c. 50 feet from creeks, lakes, ponds, and other water of the state; and
 - d. 100 feet from adjacent property lines.

3. The City of Sayre must obtain a permit to construct and a permit to supply reclaimed water from DEQ before supplying reclaimed water to any user(s) or sites not authorized in this permit. The City of Sayre will provide information to DEQ on the intended use of the reclaimed water by the new user(s), and if applicable, information on specific land application site(s) demonstrating that the requirements of OAC 252:627-3-4 for Category 5 reclaimed water are met.

C. SCHEDULE OF COMPLIANCE FOR SIGNAGE

Not applicable to this facility.

D. RECORD RETENTION OF MONITORING RESULTS

In accordance with OAC 252:627-5-1(d), the supplier of reclaimed water shall maintain MORs on-site for 3 years and make them available to DEQ upon request.

E. RECORDKEEPING OF ALL REPORTS

In accordance with OAC 252:627-5-1(e), the supplier of reclaimed water shall keep all records, including all maintenance records on-site for at least 3 years and make them available to DEQ upon request.

PART II. OTHER PERMIT REQUIREMENTS

A. GENERAL PROVISIONS

The following general provisions for supply of reclaimed water (treated wastewater) must be met in accordance with OAC 252:656-27-2:

- 1. **Prohibition against cross connections**. Neither the supplier nor the user shall allow physical connections between the reclaimed water (treated wastewater) lines and the public water supply lines.
- 2. Flow measuring devices. Supplier shall provide flow measuring devices to measure the amount of treated water being distributed to each user. Flow measurement devices shall have recording, totalizing and instantaneous indicating capabilities.

B. DISTRIBUTION SYSTEMS

The distribution system for reclaimed water shall be operated and maintained in accordance with the following requirements:

1. **Piping**. All reclaimed water (treated wastewater) piping, valves, outlets and appurtenances in distribution systems shall be colored **purple** (Pantone 522) and shall be embossed or integrally stamped with a warning that includes the following:

"CAUTION: RECLAIMED WATER - DO NOT DRINK"

For all pipes, the warning shall be located on opposite sides of all pipes and repeated every 3 feet or less.

- 2. Treated wastewater flushing system. Treated wastewater distribution system shall be designed with all appurtenances necessary to adequately flush the distribution system to prevent slime growth and the regrowth of pathogens. Flushing plan shall be maintained and followed for all treated wastewater distribution systems. The flushing system shall include provisions for disposal of flushed treated wastewater that prevent bypasses and discharges to waters of the state or elsewhere.
- **3. Maintenance**. The permittee shall maintain the structural integrity of all parts of the treated wastewater distribution system and maintain it in good working order.
- **4. Pump stations**. The permittee shall ensure that pump stations are properly maintained and operated by doing the followings:
 - a. Securing pump station(s) to prevent unauthorized access.
 - b. Maintaining pump(s) in working condition.
 - c. Keeping screen(s) free of debris to prevent clogging.
 - d. Maintaining the required alarms in working order.
 - e. Maintaining the required back-up generators and/or portable engine driven pumps in working order.
 - f. Maintaining a complete set of operational instructions, emergency procedures and maintenance schedules.